

# Comprehensive Energy Audit For

# Akiachak Water Treatment Plant



Prepared For Native Village of Akiachak

December 14, 2015

**Prepared By:** 

ANTHC-DEHE 3900 Ambassador Drive Anchorage, AK 99508

## **Table of Contents**

PREFACE	2
ACKNOWLEDGMENTS	2
1. EXECUTIVE SUMMARY	3
2. AUDIT AND ANALYSIS BACKGROUND	6
2.1 Program Description	6
2.2 Audit Description	6
2.3. Method of Analysis	7
2.4 Limitations of Study	8
3. Akiachak Water Treatment Plant	9
3.1. Building Description	9
3.2 Predicted Energy Use	13
3.2.1 Energy Usage / Tariffs	13
3.2.2 Energy Use Index (EUI)	16
3.3 AkWarm© Building Simulation	17
4. ENERGY COST SAVING MEASURES	18
4.1 Summary of Results	18
4.2 Interactive Effects of Projects	19
Appendix A – Energy Audit Report – Project Summary	25
Appendix B – Actual Fuel Use versus Modeled Fuel Use	26
Appendix C - Electrical Demands	28

## PREFACE

This energy audit was conducted using funds from the United States Department of Agriculture Rural Utilities Service as well as the State of Alaska Department of Environmental Conservation. Coordination with the State of Alaska Remote Maintenance Worker (RMW) Program and the associated RMW for each community has been undertaken to provide maximum accuracy in identifying audits and coordinating potential follow up retrofit activities.

The Energy Projects Group at the Alaska Native Tribal Health Consortium (ANTHC) prepared this document for The Akiachak Native Community, Alaska. The authors of this report are Carl Remley, Certified Energy Manager (CEM); and Kevin Ulrich, Energy Manager-in-Training (EMIT).

The purpose of this report is to provide a comprehensive document of the findings and analysis that resulted from an energy audit conducted in September of 2015 by the Energy Projects Group of ANTHC. This report analyzes historical energy use and identifies costs and savings of recommended energy conservation measures. Discussions of site-specific concerns, non-recommended measures, and an energy conservation action plan are also included in this report.

## ACKNOWLEDGMENTS

The ANTHC Energy Projects Group gratefully acknowledges the assistance of Water Treatment Plant Operators Henry Positnik and Ronald Nose, Remote Maintenance Worker Bob White, Akiachak Tribal Administrator Jonathan Lomack, and Akiachak Business Manager Mildred Evans.

## **1. EXECUTIVE SUMMARY**

This report was prepared for the Akiachak Native Community. The scope of the audit focused on the Akiachak Water Treatment Plant. The scope of this report is a comprehensive energy study, which included an analysis of building shell, interior and exterior lighting systems, heating and ventilation systems, and plug loads.

In the near future, a representative of ANTHC will be contacting both the Akiachak Native Community and the water treatment plant operators to follow up on the recommendations made in this audit report. Funding has been provided to the ANTHC through a Rural Alaska Village Grant and the Denali Commission to provide the Akiachak Native Community with assistance in understanding the report.

The total predicted energy cost for the Akiachak Water Treatment Plant is \$91,894 per year. Electricity represents the largest portion with an annual cost of \$60,861. This includes \$25,359 paid by the community and \$35,502 paid by the Power Cost Equalization (PCE) program through the State of Alaska. Fuel oil represents the remaining portion with an annual cost of \$30, 707. The building is supplied with recovered heat from the neighboring power plant at zero charge. For the purpose of the energy modeling, \$325 per year is considered for maintenance purposes.

The State of Alaska PCE program provides a subsidy to rural communities across the state to lower the electricity costs and make energy affordable in rural Alaska. In Akiachak, the cost of electricity without PCE is \$0.60/KWH and the cost of electricity with PCE is \$0.25/KWH.

There is a heat recovery system that transfers recovered heat from the generator cooling loop in the power plant to the water treatment plant. This system was constructed in 2005. The heat recovery system provides heating for all the heating loads in the water treatment plant and covers a large portion of the heating load on an annual basis. During the site visit, it was observed that while the heat recovery system was in operation there was heat also being rejected into the atmosphere through the power plant radiators. Upon inspection, it was determined that the pump and heat exchanger for the heat recovery loop in the water treatment plant are undersized and incapable of transferring all the heat provided by the power plant. This issue is detailed later in this report.

The Akiachak Water Treatment Plant has a generator located in a separate building on the building property. The generator is intended for use as a backup generator in the event that the community electricity is not available. The operators currently run the water plant generators during the daytime when the electric demand for the facility is high. Over a two year period the water treatment plant has used approximately 8,988.7 gallons of diesel fuel for the onsite generator. Assuming that 30% of the fuel used in the generator is converted into useable electricity, the two-year fuel usage is converted to an equivalent electricity production of approximately 52,952 kWh per year. Because this electricity is not produced by an electric utility, this production is not eligible for a PCE subsidy, which means that the cost of electricity produced by the water treatment plant is \$0.60/kWh for a total of approximately \$31,771 annually. If the water treatment plant were to receive the equivalent electricity production

from the community power plant, it could benefit from the PCE subsidy already given to the power plant and receive electricity at a rate of \$0.25/kWh. The total cost of this electricity would be approximately \$13,238 annually. The total savings of eliminating the daytime use of the onsite generators and receiving the equivalent power from the local power plant is approximately \$18,533 annually. This could also increase the potential benefits of the existing heat recovery system between the power plant and the water treatment plant. ANTHC is willing to help the community make the necessary adjustments to maximize the benefit of the PCE subsidy through minimizing the use of the onsite generator.

The table below lists the total usage of electricity, #1 oil, and recovered heat in the water treatment plant before and after the proposed retrofits.

Predicted Annual Fuel Use									
Fuel Use	Existing Building	With Proposed Retrofits							
Electricity	101,436 kWh	88,403 kWh							
#1 Oil	10,168 gallons	3,881 gallons							
Heat Recovery	324.82 million Btu	352.24 million Btu							

Benchmark figures facilitate comparing energy use between different buildings. The table below lists several benchmarks for the audited building. More details can be found in section 3.2.2.

Building Benchmarks							
Description	EUI	EUI/HDD	ECI				
Description	(kBtu/Sq.Ft.)	(Btu/Sq.Ft./HDD)	(\$/Sq.Ft.)				
Existing Building	434.1	32.85	\$19.81				
With Proposed Retrofits	251.4 19.03						
EUI: Energy Use Intensity - The annual site e	nergy consumption divided	by the structure's conditioned are	a.				
EUI/HDD: Energy Use Intensity per Heating E	egree Day.						
ECI: Energy Cost Index - The total annual cost of energy divided by the square footage of the conditioned space in the							
building.							

Table 1.1 below summarizes the energy efficiency measures analyzed for the Akiachak Water Treatment Plant. Listed are the estimates of the annual savings, installed costs, and two different financial measures of investment return.

		Tak PRIORITY LIST – ENERG	ole 1.1 GY EFFICIE		ASURES		
Rank	Feature	Improvement Description	Annual Energy Savings	Installed Cost	Savings to Investment Ratio, SIR <sup>1</sup>	Simple Payback (Years) <sup>2</sup>	CO2 Savings
1	Other Electrical - Circulation Pump 2 Loop B	Shut off circulation pumps during the summer months.	\$3,335	\$2,000	10.32	0.6	10,559.5
2	Lighting - Exterior Lighting 250 Watt	Replace with new energy- efficient LED lighting.	\$957	\$1,500	9.32	1.6	3,030.8
3	Heat Add Controls	Repair heat add temperature controls and shut off raw water heat add in summer.	\$8,580	\$20,000	5.81	2.3	64,464.1
4	Other Electrical - Circulation Pump 1 Loop A	Shut off circulation pumps during the summer months.	\$1,335	\$2,000	5.62	1.5	4,226.5

		Tab PRIORITY LIST – ENERG	ole 1.1 GY EFFICIE	ENCY MEA	SURES		
Rank	Feature	Improvement Description	Annual Energy Savings	Installed Cost	Savings to Investment Ratio, SIR <sup>1</sup>	Simple Payback (Years) <sup>2</sup>	CO2 Savings
5	Lighting - Garage High Bay 400	Replace with new energy- efficient LED lighting.	\$419	\$1,600	3.75	3.8	1,149.8
6	Lighting - Exterior Lighting 70 Watt	Replace with new energy- efficient LED lighting.	\$301	\$1,200	3.66	4.0	951.8
7	Lighting - WTP Lower and Second Floor	Replace with new energy- efficient LED lighting.	\$133	\$640	2.97	4.8	359.0
8	Heating, Ventilation, and Domestic Hot Water	Maximize use of heat recovery system by increasing pumps and heat exchangers to use all available heat from generators and improve controls as necessary. Also shut off boilers during summer months.	\$9,342	\$60,000	2.71	6.4	53,511.8
9	Lighting - WTP High Bay	Replace with new energy- efficient LED lighting.	\$713	\$4,000	2.59	5.6	2,049.5
10	Lighting -: Office	Replace with new energy- efficient LED lighting.	\$53	\$320	2.43	6.0	153.7
11	Lighting - Garage Task Lighting	Replace with new energy- efficient LED lighting.	\$90	\$640	2.04	7.1	258.3
12	Lighting - Garage High Bay 250	Replace with new energy- efficient LED lighting.	\$100	\$800	1.81	8.0	286.9
13	Heat Add Controls	Repair circulation heat add controls on both loops.	\$773	\$10,000	1.04	12.9	8,254.6
14	Heat Add Controls	Repair tank heat add controls and shut off tank heat add in summer.	\$399	\$6,000	0.90	15.0	4,267.4
15	Lighting - Boiler Room	Replace with new energy- efficient LED lighting.	\$24	\$480	0.73	20.0	69.2
16	Air Tightening: Garage Doors	Improve sealing around garage doors, especially at the sides and bottom.	\$220	\$3,000	0.67	13.6	2,345.4
17	Lighting - Rest Rooms & Third Floor Isle	Replace with new energy- efficient LED lighting.	\$8	\$480	0.24	59.9	23.2
1	TOTAL, all measures		Ş26,780	Ş114,660	3.22	4.3	155,961.5

#### Table Notes:

<sup>1</sup> Savings to Investment Ratio (SIR) is a life-cycle cost measure calculated by dividing the total savings over the life of a project (expressed in today's dollars) by its investment costs. The SIR is an indication of the profitability of a measure; the higher the SIR, the more profitable the project. An SIR greater than 1.0 indicates a cost-effective project (i.e. more savings than cost). Remember that this profitability is based on the position of that Energy Efficiency Measure (EEM) in the overall list and assumes that the measures above it are implemented first.

<sup>2</sup> Simple Payback (SP) is a measure of the length of time required for the savings from an EEM to payback the investment cost, not counting interest on the investment and any future changes in energy prices. It is calculated by dividing the investment cost by the expected first-year savings of the EEM.

With all of these energy efficiency measures in place, the annual utility cost can be reduced by \$26,780 per year, or 29.1% of the buildings' total energy costs. These measures are estimated to cost \$114,660, for an overall simple payback period of 4.3 years

Table 1.2 below is a breakdown of the annual energy cost across various energy end use types, such as Space Heating and Water Heating. The first row in the table shows the breakdown for the building as it is now. The second row shows the expected breakdown of energy cost for the building assuming all of the retrofits in this report are implemented. Finally, the last row shows the annual energy savings that will be achieved from the retrofits.

Annual Energ	gy Cost Est	imate							
Description	Space Heating	Water Heating	Ventilation Fans	Lighting	Other Electrical	Raw Water Heat Add	Water Circulation Heat	Tank Heat	Total Cost
Existing Building	\$26,117	\$559	\$131	\$5,039	\$35,422	\$17,903	\$4,222	\$2 <i>,</i> 500	\$91,894
With Proposed Retrofits	\$23,135	\$995	\$131	\$2,147	\$30,753	\$4,359	\$1,744	\$1,849	\$65,113
Savings	\$2,982	-\$436	\$0	\$2,892	\$4,669	\$13,544	\$2,478	\$650	\$26,780

Table 1.2

## 2. AUDIT AND ANALYSIS BACKGROUND

### 2.1 Program Description

This audit included services to identify, develop, and evaluate energy efficiency measures at the Akiachak Water Treatment Plant. The scope of this project included evaluating building shell, lighting and other electrical systems, and heating and ventilation equipment, motors and pumps. Measures were analyzed based on life-cycle-cost techniques, which include the initial cost of the equipment, life of the equipment, annual energy cost, annual maintenance cost, and a discount rate of 3.0%/year in excess of general inflation.

## 2.2 Audit Description

Preliminary audit information was gathered in preparation for the site survey. The site survey provides critical information in deciphering where energy is used and what opportunities exist within a building. The entire site was surveyed to inventory the following to gain an understanding of how each building operates:

- Building envelope (roof, windows, etc.)
- Heating and ventilation equipment
- Lighting systems and controls
- Building-specific equipment
- Water consumption, treatment (optional) & disposal

The building site visit was performed to survey all major building components and systems. The site visit included detailed inspection of energy consuming components. Summary of building occupancy schedules, operating and maintenance practices, and energy management programs provided by the building manager were collected along with the system and components to determine a more accurate impact on energy consumption.

Details collected from the Akiachak Water Treatment Plant enable a model of the building's energy usage to be developed, highlighting the building's total energy consumption, energy consumption by specific building component, and equivalent energy cost. The analysis involves distinguishing the different fuels used on site, and analyzing their consumption in different activity areas of the building.

Akiachak Water Treatment Plant is classified as being made up of the following activity areas:

1) Water Treatment Plant: 4,638 square feet

In addition, the methodology involves taking into account a wide range of factors specific to the building. These factors are used in the construction of the model of energy used. The factors include:

- Occupancy hours
- Local climate conditions
- Prices paid for energy

## 2.3. Method of Analysis

Data collected was processed using AkWarm<sup>©</sup> Energy Use Software to estimate energy savings for each of the proposed energy efficiency measures (EEMs). The recommendations focus on the building envelope; heating and ventilation; lighting, plug load, and other electrical improvements; and motor and pump systems that will reduce annual energy consumption.

EEMs are evaluated based on building use and processes, local climate conditions, building construction type, function, operational schedule, existing conditions, and foreseen future plans. Energy savings are calculated based on industry standard methods and engineering estimations.

Our analysis provides a number of tools for assessing the cost effectiveness of various improvement options. These tools utilize **Life-Cycle Costing**, which is defined in this context as a method of cost analysis that estimates the total cost of a project over the period of time that includes both the construction cost and ongoing maintenance and operating costs.

#### Savings to Investment Ratio (SIR) = Savings divided by Investment

**Savings** includes the total discounted dollar savings considered over the life of the improvement. When these savings are added up, changes in future fuel prices as projected by the Department of Energy are included. Future savings are discounted to the present to

account for the time-value of money (i.e. money's ability to earn interest over time). The **Investment** in the SIR calculation includes the labor and materials required to install the measure. An SIR value of at least 1.0 indicates that the project is cost-effective—total savings exceed the investment costs.

**Simple payback** is a cost analysis method whereby the investment cost of a project is divided by the first year's savings of the project to give the number of years required to recover the cost of the investment. This may be compared to the expected time before replacement of the system or component will be required. For example, if a boiler costs \$12,000 and results in a savings of \$1,000 in the first year, the payback time is 12 years. If the boiler has an expected life to replacement of 10 years, it would not be financially viable to make the investment since the payback period of 12 years is greater than the project life.

The Simple Payback calculation does not consider likely increases in future annual savings due to energy price increases. As an offsetting simplification, simple payback does not consider the need to earn interest on the investment (i.e. it does not consider the time-value of money). Because of these simplifications, the SIR figure is considered to be a better financial investment indicator than the Simple Payback measure.

Measures are implemented in order of cost-effectiveness. The program first calculates individual SIRs, and ranks all measures by SIR, higher SIRs at the top of the list. An individual measure must have an individual SIR>=1 to make the cut. Next the building is modified and resimulated with the highest ranked measure included. Now all remaining measures are reevaluated and ranked, and the next most cost-effective measure is implemented. AkWarm goes through this iterative process until all appropriate measures have been evaluated and installed.

It is important to note that the savings for each recommendation is calculated based on implementing the most cost effective measure first, and then cycling through the list to find the next most cost effective measure. Implementation of more than one EEM often affects the savings of other EEMs. The savings may in some cases be relatively higher if an individual EEM is implemented in lieu of multiple recommended EEMs. For example implementing a reduced operating schedule for inefficient lighting will result in relatively high savings. Implementing a reduced operating schedule for newly installed efficient lighting will result in lower relative savings, because the efficient lighting system uses less energy during each hour of operation. If multiple EEM's are recommended to be implemented, AkWarm calculates the combined savings appropriately.

Cost savings are calculated based on estimated initial costs for each measure. Installation costs include labor and equipment to estimate the full up-front investment required to implement a change. Costs are derived from Means Cost Data, industry publications, and local contractors and equipment suppliers.

## 2.4 Limitations of Study

All results are dependent on the quality of input data provided, and can only act as an approximation. In some instances, several methods may achieve the identified savings. This

report is not intended as a final design document. The design professional or other persons following the recommendations shall accept responsibility and liability for the results.

## 3. Akiachak Water Treatment Plant

## 3.1. Building Description

The 4,638 square foot Akiachak Water Treatment Plant was constructed in 1990, with a normal occupancy of 1 person. The number of hours of operation for this building average 5 hours per day, considering all seven days of the week.

The Akiachak Water Treatment Plant serves as the water distribution center for the residents of the community and houses all the components for two active distribution loops. A third loop is going to be installed when the town completes the remaining portion of the water and sewer project. A large garage area is also located in the water treatment plant.

The Akiachak Water Treatment Plant has two distribution loops that are used to provide water service to the western side of the community. The two loops combine to serve all the residential and public facilities with distributed water and they are a combined 9000 ft. long approximately. The eastern side of the community does not have piped water. The water treatment plant was built with the capacity to handle a third loop for the eastern side of town. Construction on a new water distribution loop for the eastern side of town will begin in summer 2016. The construction of the new water loop adds to the importance of energy efficiency because the additional operations could further increase inefficiencies and operational deficiencies that may exist because of the increased energy demand.

Water is pumped into the water treatment plant from a well approximately 200 feet from the building. The water is pumped through an open-air filtration system with a large mixing tank for chemical injection of soda ash, lime, and chlorine. The water is injected with the chemicals and mixed before being sent to the 318,000 gallon water storage tank.

#### **Description of Building Shell**

The exterior walls are constructed with stressed skin panels that are six inches thick. The panels have five inches of polyurethane foam insulation that is slightly damaged and there is approximately 7,175 square feet of wall space in the building.

The building has a cathedral ceiling with standard framing and 24-inch spacing. The roof has six inches of polyurethane foam insulation that is slightly damaged and there is approximately 4,782 square feet of roof space in the building.

The building is built on grade with a slab foundation. The foundation has four inches of XPS blue foam board throughout the entire floor area and there are approximately 4,638 square feet of floor space in the building.

There are four windows in the building, each of which is wood-framed and double-paned. There is a total of 52 square feet of window space in the building. There are four exterior doors in the building. Each of the doors is metal with an insulated core and there is a total of approximately 84 square feet of door space in the building. There are also three large metal garage doors in the garage portion of the building. These doors are uninsulated and are not sealed properly on the sides or bottom. There is a total of approximately 456 square feet of garage door space in the building.

#### **Description of Heating Plants**

The Heating Plants used in the building are:

BP 1 Weil McLean	
Nameplate Information:	BL 1088 WF Boiler 21.5 GPH Firing Rate with Beckett CF
2500 -W Burner with high-low contr	rols.
Fuel Type:	#1 Oil
Input Rating:	2,132,000 BTU/hr
Steady State Efficiency:	78 %
Idle Loss:	1.5 %
Heat Distribution Type:	Glycol
Boiler Operation:	All Year
BP 2 Weil McLean	
Nameplate Information:	Weil McLean BL 1088 WF Boiler with Beckett CF 2500-
W Burner with high low controls	
Fuel Type:	#1 Oil
Input Rating:	2,132,000 BTU/hr
Steady State Efficiency:	78 %
Idle Loss:	1.5 %
Heat Distribution Type:	Glycol
Boiler Operation:	All Year
Heat Recovery System	
Fuel Type:	Heat Recovery
Input Rating:	998,000 BTU/hr
Steady State Efficiency:	99 %
Idle Loss:	1.5 %
Heat Distribution Type:	Glycol
Boiler Operation:	All Year

#### Space Heating Distribution Systems

There are seven unit heaters in the building that are used to provide space heat in the occupied zones. All of the unit heaters are Dunham-Bush models that combine to produce approximately 400,000 BTU/hr of heating.

There are five pumps associated with the heating distribution processes. Two pumps, CP-4A and CP-4B, circulate heated glycol to the raw water heat-add heat exchanger at a rate of 150 GPM. Two pumps, CP-5A and CP-5B, circulate heated glycol to all the unit heaters and five

heat-add heat exchangers. One pump, CP-6, circulates glycol through the heat recovery heat exchanger. It should be noted that CP-6 is a Grundfos Series L Model TP 100-80 that is operating at a maximum rating of 285 Watts. This pump is not the same pump indicated in the heat recovery specifications.

#### **Domestic Hot Water System**

There are two hot water heaters that are used for hot water purposes in the bathroom, shower, and utility sink. The two heaters are Amtrol Model WH-7C-DW with a 41 gallon storage capacity for each tank. The domestic hot water system uses an estimated 5 gallons of water per day. Included with the heaters is a small pump, CP-7, that is a Grundfos Model UP15-18BUC7 rated for 85 Watts. The pump operates whenever there is a call for hot water.

#### **Heat Recovery Information**

There is a heat recovery system that transfers heat from the generator cooling loop in the power plant to the water treatment plant that heats the glycol before going into the boilers. The system produces an average of 998,000 BTU/hr during the winter season and covers a significant portion of the water treatment plant heating load. When the heat recovery system is in full operation, the power plant is still releasing heat through the radiators because the heat recovery system does not have the capacity to transfer heat quick enough for effective generator cooling. Approximately 150,000 BTU/hr is being transferred through the power plant radiators. The winter power plant load is approximately 300-400 kW on average.

#### **Description of Building Ventilation System**

There are exhaust fans present in the two rest rooms that operate when the rest room lights are turned on. The fan in one room operates at 50 Watts and produces 72 CFM while the fan in the second room operates at 50 Watts and produces 84 CFM. The rest room use is approximately 30 minutes per day.

There is an exhaust fan present in the office that operates during normal operator hours. The fan operates at 100 Watts and produces 380 CFM. The usage is approximately 5 hours per day.

There is a large exhaust fan in the storage area that operates for approximately 15 minutes per day when the room is occupied by an operator. The fan operates at 298 Watts and produces 3,730 CFM.

#### <u>Lighting</u>

The main water treatment plant space has 10 high bay 250 Watt metal halide lights. These lights operate approximately five hours per day when the operators are working and consume approximately 2,554 kWh annually.

The garage has 4 high bay 400 Watt metal halide lights. These lights operate approximately 3.5 hours per day when the garage is occupied and consume approximately 1,141 kWh annually.

The garage has 2 high bay 250 Watt metal halide lights. These lights operate approximately 3.5 hours per day when the garage is occupied and consume approximately 358 kWh annually.

There are eight fixtures with two T8 4-ft. light bulbs in each fixture that are used for task lighting in the garage space. The lights operate approximately 3.5 hours per day when the garage is occupied and consume approximately 530 kWh annually.

The first and second levels of the water treatment plant space have eight fixtures with two T8 4-ft. fluorescent light bulbs in each fixture. These lights operate approximately five hours per day when the operators are working and consume approximately 841 kWh annually.

The office has four fixtures with two T8 4-ft. fluorescent light bulbs in each fixture. The lights operate approximately five hours per day when the operators are working and consume approximately 315 kWh annually.

The boiler room has six fixtures with two T8 4-ft. fluorescent light bulbs in each fixture. The lights operate approximately 1.5 hours per day and consume approximately 142 kWh annually.

The third floor area has six fixtures with two T8 4-ft. fluorescent light bulbs in each fixture. The lights operate approximately 30 minutes per day and consume approximately 47 kWh annually.

The exterior of the building has three 250 Watt high pressure sodium lights that operate constantly from September to April. These lights consume approximately 1,790 kWh annually. The exterior of the building also has four fixtures with a single 70 Watt light bulb in each fixture. These lights operate constantly from September to April and consume approximately 682 kWh annually.

#### Plug Loads

The water treatment plant has a variety of power tools, a telephone, and some other miscellaneous loads that require a plug into an electrical outlet. The use of these items is infrequent and consumes a small portion of the total energy demand of the building.

#### Major Equipment

There are two circulation pumps on Loop A that are used to circulate water through the Loop A distribution loop to residents of the community. The pumps are rated for 1.5 HP and one of the pumps operates constantly all year long. The pumps consume approximately 8,898 kWh annually.

There are two circulation pumps on Loop B that are used to circulate water through the Loop B distribution loop to residents of the community. The pumps are rated for 3.5 HP and one of the pumps operates constantly all year long. The pumps consume approximately 22,231 kWh annually.

There is a well pump that is used to pump water from the raw water intake well to the water treatment plant. The pump is rated for 6.8 HP and operates approximately seven hours per day all year long. The pump consumes approximately 12,970 kWh annually.

There are three pressure pumps that are used to maintain the necessary pressure for the operations of the water distribution system. The pumps are rated for 10 HP and operate 14% of the time all year long. The pumps consume approximately 9,338 kWh annually.

There is a clarifier pump that is used to circulate the treated water through the clarifier. The pump is rated for 253 Watts and operates constantly all year long. The pump consumes approximately 2,218 kWh annually.

There is a backwash pump that is used to backwash the treatment system for general maintenance purposes. The pump is rated for 3,805 Watts and operates approximately 20 minutes per day all year long. The pump consumes approximately 397 kWh annually.

There is an air compressor that is used for a variety of maintenance and repair tasks in the water treatment plant and the garage. The compressor is rated for 320 Watts and is estimated to operate approximately 3% of the time all year long. The compressor consumes approximately 84 kWh annually.

There is a lift station pump that is used to collect the sewage from the resident houses and pump it to a sewage lagoon. The pump is rated for 6.8 HP and operates approximately 4% of the time all year long. The pump consumes approximately 1,779 kWh annually.

There are a variety of miscellaneous pumps and controls in the water treatment plant associated with the general operations of the water treatment plant. The equipment is estimated to use approximately 1,122 kWh annually.

## 3.2 Predicted Energy Use

### 3.2.1 Energy Usage / Tariffs

The electric usage profile charts (below) represents the predicted electrical usage for the building. If actual electricity usage records were available, the model used to predict usage was calibrated to approximately match actual usage. The electric utility measures consumption in kilowatt-hours (kWh) and maximum demand in kilowatts (kW). One kWh usage is equivalent to 1,000 watts running for one hour. One KW of electric demand is equivalent to 1,000 watts running at a particular moment. The basic usage charges are shown as generation service and delivery charges along with several non-utility generation charges.

The fuel oil usage profile shows the fuel oil usage for the building. Fuel oil consumption is measured in gallons. One gallon of #1 Fuel Oil provides approximately 132,000 BTUs of energy.

The Akiachak Native Community Electricity Company provides electricity to the residents of Akiachak as well as all the commercial and public facilities.

Table 3.1 – Averag	e Energy Cost
Description	Average Energy Cost
Electricity	\$ 0.60/kWh
#1 Oil	\$ 3.02/gallons
Heat Recovery	\$ 1.00/million Btu

The average cost for each type of fuel used in this building is shown below in Table 3.1. This figure includes all surcharges, subsidies, and utility customer charges:

#### 3.2.1.1 Total Energy Use and Cost Breakdown

At current rates, WTP pays approximately \$91,894 annually for electricity and other fuel costs for the Akiachak Water Treatment Plant.

Figure 3.1 below reflects the estimated distribution of costs across the primary end uses of energy based on the AkWarm<sup>©</sup> computer simulation. Comparing the "Retrofit" bar in the figure to the "Existing" bar shows the potential savings from implementing all of the energy efficiency measures shown in this report.



### Figure 3.1 Annual Energy Costs by End Use

Figure 3.2 below shows how the annual energy cost of the building splits between the different fuels used by the building. The "Existing" bar shows the breakdown for the building as it is now; the "Retrofit" bar shows the predicted costs if all of the energy efficiency measures in this report are implemented.

### Figure 3.2 Annual Energy Costs by Fuel Type



Figure 3.3 below addresses only Space Heating costs. The figure shows how each heat loss component contributes to those costs; for example, the figure shows how much annual space heating cost is caused by the heat loss through the Walls/Doors. For each component, the space heating cost for the Existing building is shown (blue bar) and the space heating cost assuming all retrofits are implemented (yellow bar) are shown.



Figure 3.3 Annual Space Heating Cost by Component

The tables below show AkWarm's estimate of the monthly fuel use for each of the fuels used in the building. For each fuel, the fuel use is broken down across the energy end uses. Note, in the tables below "DHW" refers to Domestic Hot Water heating.

<b>Electrical Consun</b>	nption	(kWh	)									
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sept	Oct	Nov	Dec
Space Heating	2821	2568	2802	2681	2734	2630	2712	2715	2639	2760	2700	2821
DHW	63	58	63	61	63	61	63	63	61	63	61	63
Ventilation Fans	19	17	19	18	19	18	19	19	18	19	18	19
Lighting	862	786	862	661	503	487	503	503	672	862	835	862
Other Electrical	5011	4566	5011	4849	5011	4849	5011	5011	4849	5011	4849	5011
Raw Water Heat Add	25	23	26	26	30	29	31	31	29	28	25	25
Water Circulation Heat	6	5	6	6	7	7	7	7	7	7	6	6
Tank Heat	7	6	7	5	2	1	0	0	2	4	5	7

Fuel Oil #1 Consu	Imptic	on (Gal	llons)									
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sept	Oct	Nov	Dec
Space Heating	419	371	337	176	29	0	0	0	0	129	272	421
DHW	3	2	3	3	3	3	4	4	3	3	3	3
Raw Water Heat Add	420	385	437	467	536	539	562	560	532	503	439	420
Water Circulation Heat	99	91	103	110	126	127	133	132	126	119	103	99
Tank Heat	122	110	112	85	44	12	0	5	29	73	95	122

Recovered Heat Consumption (Million Btu)												
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sept	Oct	Nov	Dec
Space Heating	12	11	10	4	0	0	0	0	0	3	7	12
Raw Water Heat Add	14	13	15	15	18	18	18	18	17	17	15	14
Water Circulation Heat	3	3	3	4	4	4	4	4	4	4	3	3
Tank Heat	4	4	4	3	1	0	0	0	1	2	3	4

### 3.2.2 Energy Use Index (EUI)

Energy Use Index (EUI) is a measure of a building's annual energy utilization per square foot of building. This calculation is completed by converting all utility usage consumed by a building for one year, to British Thermal Units (Btu) or kBtu, and dividing this number by the building square footage. EUI is a good measure of a building's energy use and is utilized regularly for comparison of energy performance for similar building types. The Oak Ridge National Laboratory (ORNL) Buildings Technology Center under a contract with the U.S. Department of Energy maintains a Benchmarking Building Energy Performance Program. The ORNL website determines how a building's energy use compares with similar facilities throughout the U.S. and in a specific region or state.

Source use differs from site usage when comparing a building's energy consumption with the national average. Site energy use is the energy consumed by the building at the building site only. Source energy use includes the site energy use as well as all of the losses to create and distribute the energy to the building. Source energy represents the total amount of raw fuel that is required to operate the building. It incorporates all transmission, delivery, and production losses, which allows for a complete assessment of energy efficiency in a building. The type of utility purchased has a substantial impact on the source energy use of a building. The EPA has determined that source energy is the most comparable unit for evaluation purposes and overall global impact. Both the site and source EUI ratings for the building are provided to understand and compare the differences in energy use.

Building Site EUI = <u>(Electric Usage in kBtu + Fuel Oil Usage in kBtu)</u> Building Square Footage Building Source EUI = (Electric Usage in kBtu X SS Ratio + Fuel Oil Usage in kBtu X SS Ratio) Building Square Footage where "SS Ratio" is the Source Energy to Site Energy ratio for the particular fuel.

Table 3.4
Akiachak Water Treatment Plant EUI Calculations

		Site Energy Use	Source/Site	Source Energy Use					
Energy Type	<b>Building Fuel Use per Year</b>	per Year, kBTU	Ratio	per Year, kBTU					
Electricity	101,436 kWh	346,200	3.340	1,156,307					
#1 Oil	10,168 gallons	1,342,180	1.010	1,355,601					
Heat Recovery	324.82 million Btu	324,823	1.280	415,773					
Total		2,013,202		2,927,681					
BUILDING AREA		4,638	Square Feet						
BUILDING SITE EUI		434	kBTU/Ft²/Yr						
BUILDING SOURCE EUI 631 kBTU/Ft <sup>2</sup> /Yr									
* Site - Source Ratio data is provided by the Energy Star Performance Rating Methodology for Incorporating									
Source Energy Use do	cument issued March 2011.								

#### Table 3.5

Building Benchmarks								
Description	EUI (kBtu/Sq.Ft.)	EUI/HDD (Btu/Sq.Ft./HDD)	ECI (\$/Sq.Ft.)					
Existing Building	434.1	32.85	\$19.81					
With Proposed Retrofits	251.4	19.03	\$14.04					
EUI: Energy Use Intensity - The annual site e EUI/HDD: Energy Use Intensity per Heating	energy consumption divided Degree Day.	I by the structure's conditioned are	:a.					

ECI: Energy Cost Index - The total annual cost of energy divided by the square footage of the conditioned space in the building.

#### 3.3 AkWarm© Building Simulation

An accurate model of the building performance can be created by simulating the thermal performance of the walls, roof, windows and floors of the building. The heating and ventilation systems and central plant are modeled as well, accounting for the outside air ventilation required by the building and the heat recovery equipment in place.

The model uses local weather data and is trued up to historical energy use to ensure its accuracy. The model can be used now and in the future to measure the utility bill impact of all types of energy projects, including improving building insulation, modifying glazing, changing air handler schedules, increasing heat recovery, installing high efficiency boilers, using variable air volume air handlers, adjusting outside air ventilation and adding cogeneration systems.

For the purposes of this study, the Akiachak Water Treatment Plant was modeled using AkWarm© energy use software to establish a baseline space heating energy usage. Climate data from Akiachak was used for analysis. From this, the model was be calibrated to predict the impact of theoretical energy savings measures. Once annual energy savings from a particular

measure were predicted and the initial capital cost was estimated, payback scenarios were approximated. Equipment cost estimate calculations are provided in Appendix D.

#### Limitations of AkWarm© Models

• The model is based on typical mean year weather data for Akiachak. This data represents the average ambient weather profile as observed over approximately 30 years. As such, the gas and electric profiles generated will not likely compare perfectly with actual energy billing information from any single year. This is especially true for years with extreme warm or cold periods, or even years with unexpectedly moderate weather.

• The heating load model is a simple two-zone model consisting of the building's core interior spaces and the building's perimeter spaces. This simplified approach loses accuracy for buildings that have large variations in heating loads across different parts of the building.

The energy balances shown in Section 3.1 were derived from the output generated by the AkWarm<sup>©</sup> simulations.

## 4. ENERGY COST SAVING MEASURES

### 4.1 Summary of Results

The energy saving measures are summarized in Table 4.1. Please refer to the individual measure descriptions later in this report for more detail.

	Table 4.1 Akiachak Water Treatment Plant, Akiachak, Alaska PRIORITY LIST – ENERGY EFFICIENCY MEASURES										
Rank	Feature	Improvement Description	Annual Energy Savings	Installed Cost	Savings to Investment Ratio, SIR	Simple Payback (Years)	CO2 Savings				
1	Other Electrical - Circulation Pump 2 Loop B	Shut off circulation pumps during the summer months.	\$3,335	\$2,000	10.32	0.6	10,559.5				
2	Lighting - Exterior Lighting 250 Watt	Replace with new energy- efficient LED lighting.	\$957	\$1,500	9.32	1.6	3,030.8				
3	Heat Add Controls	Repair heat add temperature controls and shut off raw water heat add in summer.	\$8,580	\$20,000	5.81	2.3	64,464.1				
4	Other Electrical - Circulation Pump 1 Loop A	Shut off circulation pumps during the summer months.	\$1,335	\$2,000	5.62	1.5	4,226.5				
5	Lighting - Garage High Bay 400	Replace with new energy- efficient LED lighting.	\$419	\$1,600	3.75	3.8	1,149.8				

Table 4.1
Akiachak Water Treatment Plant, Akiachak, Alaska
PRIORITY LIST – ENERGY EFFICIENCY MEASURES

					LAJONLJ		
			Annual		Savings to	Simple	
			Energy	Installed	Investment	Payback	CO <sub>2</sub>
Rank	Feature	Improvement Description	Savings	Cost	Ratio, SIR	(Years)	Savings
6	Lighting - Exterior Lighting 70 Watt	Replace with new energy- efficient LED lighting.	\$301	\$1,200	3.66	4.0	951.8
7	Lighting - WTP Lower and Second Floor	Replace with new energy- efficient LED lighting.	\$133	\$640	2.97	4.8	359.0
8	Heating, Ventilation, and Domestic Hot Water	Maximize use of heat recovery system by increasing pumps and heat exchangers to use all available heat from generators and improve controls as necessary. Also shut off boilers during summer months.	\$9,342	\$60,000	2.71	6.4	53,511.8
9	Lighting - WTP High Bay	Replace with new energy- efficient LED lighting.	\$713	\$4,000	2.59	5.6	2,049.5
10	Lighting -: Office	Replace with new energy- efficient LED lighting.	\$53	\$320	2.43	6.0	153.7
11	Lighting - Garage Task Lighting	Replace with new energy- efficient LED lighting.	\$90	\$640	2.04	7.1	258.3
12	Lighting - Garage High Bay 250	Replace with new energy- efficient LED lighting.	\$100	\$800	1.81	8.0	286.9
13	Heat Add Controls	Repair circulation heat add controls on both loops.	\$773	\$10,000	1.04	12.9	8,254.6
14	Heat Add Controls	Repair tank heat add controls and shut off tank heat add in summer.	\$399	\$6,000	0.90	15.0	4,267.4
15	Lighting - Boiler Room	Replace with new energy- efficient LED lighting.	\$24	\$480	0.73	20.0	69.2
16	Air Tightening: Garage Doors	Improve sealing around garage doors, especially at the sides and bottom.	\$220	\$3,000	0.67	13.6	2,345.4
17	Lighting - Rest Rooms & Third Floor Isle	Replace with new energy- efficient LED lighting.	\$8	\$480	0.24	59.9	23.2
	TOTAL, all measures		\$26,780	\$114,660	3.22	4.3	155,961.5

## 4.2 Interactive Effects of Projects

The savings for a particular measure are calculated assuming all recommended EEMs coming before that measure in the list are implemented. If some EEMs are not implemented, savings for the remaining EEMs will be affected. For example, if ceiling insulation is not added, then savings from a project to replace the heating system will be increased, because the heating system for the building supplies a larger load.

In general, all projects are evaluated sequentially so energy savings associated with one EEM would not also be attributed to another EEM. By modeling the recommended project sequentially, the analysis accounts for interactive affects among the EEMs and does not "double count" savings.

Interior lighting, plug loads, facility equipment, and occupants generate heat within the building. Lighting-efficiency improvements are anticipated to slightly increase heating requirements. Heating penalties were included in the lighting project analysis.

## 4.3 Building Shell Measures

### 4.3.1 Air Sealing Measures

Rank	Location	ition Existing Air Leakage Level (cfm@50/75 Pa) Rec			commended Air Leakage Reduct	ion (cfm@50/75 Pa)		
16 Garage Doors Air Tightne			Tightness estimated as: 3000 cfm	at 50 Pascals	;	Improve sealing around gara at the sides and bottom.	ge doors, especially	
Installat	Installation Cost \$3,		00	Estimated Life of Measure (yrs)		10	Energy Savings (/yr) \$2	
Breakeven Cost \$2,01		16	Savings-to-Investment Ratio		0.7	.7 Simple Payback yrs 14		
Auditor	Notor: Thor	o aro largo coa		around the sides and bettem of t	ha garaga dag	or th	hat appear because the deer deer	s not fully close and

Auditors Notes: There are large spaces around the sides and bottom of the garage door that appear because the door does not fully close and cover the open space in the wall. The bottom of the door could have a simple rug or skirt attached while the side could be covered by an insulation layer to stop the air penetration.

## 4.4 Mechanical Equipment Measures

### 4.4.1 Heating/ Domestic Hot Water Measure

Rank	Recommendation						
8	8 Maximize use of heat recovery system by increasing pumps and heat exchangers to use all available heat from generators and improve						
	controls as r	necessary. Also sh	nut off boilers during summer mon	ths.			
Installat	Installation Cost \$60,000 Estimated Life of Measure (yrs) 20 Energy Savings (/yr) \$9,34						
Breakev	en Cost	\$162,593	Savings-to-Investment Ratio	2.7	Simple Payback yrs	6	
Auditors	Notes: The	heat recovery sys	tem does not operate at full capac	ity as there is hea	at actively being released by the	power plant radiators	
despite the heat recovery system operating fully. The pump and heat exchanger in the water plant should be resized and the piping changed for a							
larger di	ameter to acc	ommodate more	heat and allow the heat recovery	system to be max	kimized.		

## 4.5 Electrical & Appliance Measures

### 4.5.1 Lighting Measures

The goal of this section is to present any lighting energy conservation measures that may also be cost beneficial. It should be noted that replacing current bulbs with more energy-efficient equivalents will have a small effect on the building heating loads. The building heating load will see a small increase, as the more energy efficient bulbs give off less heat.

#### 4.5.1a Lighting Measures – Replace Existing Fixtures/Bulbs

Rank	Location		Existing Condition	R	ecommendation		
2 Exterior Lighting 250		nting 250	3 HPS 250 Watt StdElectronic with M	anual Switching	Replace with new energy-efficient LED lighting.		
Watt							
Installation Cost \$1		\$1,50	D0 Estimated Life of Measure (yrs)	20	Energy Savings (/yr)	\$957	
Breakev	ven Cost	\$13,98	33 Savings-to-Investment Ratio	s-to-Investment Ratio 9.3 Simple Payback yrs			
Auditors per fixtu	s Notes: Rep ire to be adde	lace existing HP d for a total of	2S light fixtures with LED fixtures with 15 new light bulbs.	five 25 Watt LE	D light bulbs. The exterior has 3 f	ixtures with five bulbs	

Rank	Location	E	existing Condition	R	ecommendation	
5 Garage High Bay 400			MH 400 Watt StdElectronic with M	anual Switching	Replace with new energy-ef	ficient LED lighting.
Installat	ion Cost	\$1,600	0 Estimated Life of Measure (yrs)	20	Energy Savings (/yr)	\$419
Breakeven Cost \$6,		\$6,004	4 Savings-to-Investment Ratio	3.8	Simple Payback yrs	4
Auditors	Notes: Rep	lace existing me	tal halide light fixtures with LED fixtu	ures with five 25	Watt LED light bulbs. This roo	om has 4 fixtures with five
bulbs per fixture to be added for a			al of 20 new light bulbs.			

Rank	Rank Location		Existing Condition	Re	ecommendation	
6 Exterior Lighting 70 Watt		nting 70 Watt	4 HPS 70 Watt StdElectronic with Ma	nual Switching	Replace with new energy-efficient LED lighting.         Energy Savings (/yr)       \$303	
Installat	ion Cost	\$1,2	00 Estimated Life of Measure (yrs)	20	Energy Savings (/yr)	\$301
Breakeven Cost \$4,		\$4,3	92 Savings-to-Investment Ratio	3.7	Simple Payback yrs	4
Auditors	s Notes: Rep	lace existing H	PS light fixtures with LED fixtures with	17 Watt LED eq	uivalents. The exterior has 4 fixtu	res to be added for a
total of 4	4 new light bu	lbs.				

Rank Location			Existing Condition	F	Rec	commendation			
7 WTP lower and second		and second 8	8 FLUOR (2) T8 4' F32T8 32W Standa	rd Instant		Replace with new energy-efficient LED lighting.			
floor			StdElectronic with Manual Switching						
Installation Cost \$		\$640	0 Estimated Life of Measure (yrs)	2	20	Energy Savings (/yr)	\$133		
Breakev	ven Cost	\$1,898	8 Savings-to-Investment Ratio	3.	3.0	Simple Payback yrs			
Breakeven Cost         \$1,898         Savings-to-Investment Ratio         3.0         Simple Payback         yrs           Auditors Notes:         Replace existing fluorescent light fixtures with 17 Watt 4-ft. LED equivalents.         This room has 8 fixtures with the for a total of 16 light bulbs to be replaced.					th two bulbs per fixture				

Rank	Location	E	Existing Condition	R	ecommendation			
9 WTP High Bay		ay 1	10 MH 250 Watt StdElectronic with N	/anual	Replace with n	Replace with new energy-efficient LED lighting.		
			Switching					
Installation Cost \$4			0 Estimated Life of Measure (yrs)	20	0 Energy Savings	(/yr)	\$713	
Breakev	ven Cost	\$10,351	1 Savings-to-Investment Ratio	2.6	6 Simple Paybac	k yrs	6	
Breakeven Cost\$10,351Savings-to-Investment Ratio2.6Simple PaybackyrsAuditors Notes:Replace existing metal halide light fixtures with LED fixtures with five 25 Watt LED light bulbs.This room has 10 fixtures with five subspective fixture to be added for a total of 50 new light bulbs.						has 10 fixtures with		

Rank	Location	E	xisting Condition	Recommendation				
10	Office	4	4 FLUOR (2) T8 4' F32T8 32W Standard Instant			Replace with new energy-efficient LED lighting.		
		S <sup>1</sup>	tdElectronic with Manual Switching ensor					
Installat	tion Cost	\$320	Estimated Life of Measure (yrs)	2	20	Energy Savings (/yr)		\$53
Breakeven Cost		\$777	777 Savings-to-Investment Ratio		2.4	Simple Payback yrs		6

Auditors Notes: Replace existing fluorescent light fixtures with 17 Watt 4-ft. LED equivalents. This room has 4 fixtures with two bulbs per fixture for a total of 8 light bulbs to be replaced.

Rank Location			Existing Condition	R	ecommendation				
11 Garage Task Lighting			8 FLUOR (2) T8 4' F32T8 32W Standard Instant		Replace with new energy-efficient LED lighting.				
			StdElectronic with Manual Switching						
Installation Cost \$		\$6	540 Estimated Life of Measure (yrs)	20	0 Energy Savings (/yr)	\$90			
Breakev	ven Cost	\$1,3	\$1,305 Savings-to-Investment Ratio		0 Simple Payback yrs	7			
Auditors for a tot	Auditors Notes: Replace existing fluorescent light fixtures with 17 Watt 4-ft. LED equivalents. This room has 8 fixtures with two bulbs per fixture for a total of 16 light bulbs to be replaced.								

Rank Location			xisting Condition	R	ecommendation				
12 Garage High Bay 250			2 MH 250 Watt StdElectronic with Manual Switching		g Replace with new energy-effici	Replace with new energy-efficient LED lighting.			
Installation Cost \$		\$800	0 Estimated Life of Measure (yrs)		0 Energy Savings (/yr)	\$100			
Breakeven Cost \$3		\$1,449	449 Savings-to-Investment Ratio		8 Simple Payback yrs	8			
Auditors	Auditors Notes: Replace existing metal halide light fixtures with LED fixtures with five 25 Watt LED light bulbs. This room has 2 fixtures with five								
bulbs pe	bulbs per fixture to be added for a total of 10 new light bulbs.								

Rank	Location	Ex	isting Condition	ecommendation					
15	Boiler Room	n 61	LUOR (2) T8 4' F32T8 32W Standa	Replace with ne	Replace with new energy-efficient LED lighting.				
		Ste	dElectronic with Manual Switching,						
Sensor									
Installation Cost		\$480	Estimated Life of Measure (yrs)	2	0 Energy Savings	(/yr)	\$24		
Breakev	en Cost	\$349	Savings-to-Investment Ratio	0.	7 Simple Paybac	< yrs	20		
Auditors	Auditors Notes: Replace existing fluorescent light fixtures with 17 Watt 4-ft. LED equivalents. This room has 6 fixtures with two bulbs per fixture								
for a tot	for a total of 12 light bulbs to be replaced.								

Rank	Location	E	Existing Condition Re			ecommendation			
17	Rest Rooms	& Third 6	6 FLUOR (2) T8 4' F32T8 32W Standard Instant			Replace with new energy-efficient LED lighting.			
	Floor Isle	S	StdElectronic with Manual Switching, Occupancy						
	Sensor								
Installat	Installation Cost		Estimated Life of Measure (yrs)	2	20	Energy Savings (/yr)	\$8		
Breakev	en Cost	\$116	5 Savings-to-Investment Ratio	0	).2	Simple Payback yrs	60		
Auditors	Auditors Notes: Replace existing fluorescent light fixtures with 17 Watt 4-ft. LED equivalents. This room has 6fixtures with two bulbs per fixture								
for a tot	for a total of 12 light bulbs to be replaced.								
	0	•							

4.5.2 Other Electrical Measures

Rank	Location		Description of Existing		Effi	ficiency Recommendation		
1	Circulation I	Pump 2 Loop	Circulation Pump with Manual Switching		Shut off circulation pumps during the summer			
В						months.		
Installat	Installation Cost		00 Estimated Life of Measure (yrs)		7	Energy Savings (/yr)	\$3,335	
Breakev	en Cost	\$20,64	42 Savings-to-Investment Ratio	10	0.3	Simple Payback yrs	1	
Auditors Notes: Shut off circulation pump during summer months.								

Rank Location			Description of Existing Eff			ficiency Recommendation			
4	Circulation I	Pump 1 Loop	Circulation Pump with Manual Switching			Shut off circulation pumps during the summer			
	А					months.			
Installation Cost \$		\$2,00	D0 Estimated Life of Measure (yrs)	1	10	Energy Savings (/yr)	\$1,335		
Breakev	en Cost	\$11,23	9 Savings-to-Investment Ratio 5.6		5.6	Simple Payback yrs	1		
Auditors	Auditors Notes: Shut off circulation pump during summer months.								

## 4.5.3 Other Measures

Rank	Location	C	Description of Existing	E	fficiency Recommendation					
3 Raw Water Heat Add			Raw Water Heat Add Load	Repair heat add temperature controls and shut off						
				raw water heat	raw water heat add in summer.					
Installation Cost \$20,			0 Estimated Life of Measure (yrs)	1!	5 Energy Savings	(/yr)	\$8,580			
Breakeven Cost \$116			6 Savings-to-Investment Ratio	5.8	8 Simple Payback	x yrs	2			
Auditors	Notes: The	existing controls	s do not function and as a result the	re is a constant o	call for heat to the	raw water heat	add loop at all times			
through	out the year.	This recommend	dation is to repair or replace the co	ntrols for the ray	w water heat add l	oop, set the hea	it add temperature to			
40 deg.	40 deg. F, and shut off the raw water heat add in the summer months when there is no concern about potential freeze-ups.									

Rank Location			escription of Existing	Ef	Efficiency Recommendation			
13 Water Circulation Loops			Water Circulation Heat Load		Repair circulation heat add controls on both loops.			
Installation Cost \$10,		\$10,000	Estimated Life of Measure (yrs)	15	Energy Savings (/yr)	\$773		
Breakev	en Cost	\$10,443	\$10,443 Savings-to-Investment Ratio		Simple Payback yrs	13		
Auditors	Notes: The	existing controls	do not function and as a result ther	e is a constant c	all for heat to the water circulation	on loops. This		
recomm	endation is to	repair or replace	e the controls for the heat-add on t	he water circulat	tion loops and set the distributior	n temperature to 40		
deg. F.								

Rank Location			Description of Existing E			Effi	ficiency Recommendation			
14 Water Storage Tank			Tank Heat Load		Repair tank heat add controls and shut off tank heat					
							add in summer.			
Installation Cost \$6,		\$6,0	000	Estimated Life of Measure (yrs)		15	Energy Savings	(/yr)	\$399	
Breakev	en Cost	\$5 <i>,</i> 3	394 Savings-to-Investment Ratio		(	0.9	Simple Payback	yrs	15	
Auditors recomm	Breakeven Cost       S5,394       Savings-to-investment katio       0.9       Simple Payback       yrs       1         Auditors Notes:       The existing controls do not function and as a result there is a constant call for heat to the water storage tank. This recommendation is to repair or replace the controls for the heat-add on the water storage tank and set the storage temperature to 40 deg. F.								ank. This ature to 40 deg. F.	

## **5. ENERGY EFFICIENCY ACTION PLAN**

Through inspection of the energy-using equipment on-site and discussions with site facilities personnel, this energy audit has identified several energy-saving measures. The measures will reduce the amount of fuel burned and electricity used at the site. The projects will not degrade the performance of the building and, in some cases, will improve it.

Several types of EEMs can be implemented immediately by building staff, and others will require various amounts of lead time for engineering and equipment acquisition. In some cases, there are logical advantages to implementing EEMs concurrently. For example, if the same electrical contractor is used to install both lighting equipment and motors, implementation of these measures should be scheduled to occur simultaneously.

In the near future, a representative of ANTHC will be contacting both the Akiachak Native Community and the water treatment plant operator to follow up on the recommendations made in this audit report. Funding has been provided to ANTHC through a Rural Alaska Village Grant and the Denali Commission to provide the Akiachak Native Community with assistance in understanding the report and implementing the recommendations. ANTHC will work to complete the recommendations within the 2016 calendar year.

## APPENDICES

# Appendix A – Energy Audit Report – Project Summary

<b>ENERGY AUDIT REPORT – PROJECT SU</b>	MMARY
General Project Information	
PROJECT INFORMATION	AUDITOR INFORMATION
Building: Akiachak Water Treatment Plant	Auditor Company: ANTHC-DEHE
Address: P O Box 51070	Auditor Name: Carl Remley and Kevin Ulrich
City: Akiachak	Auditor Address: 3900 Ambassador Drive
Client Name: Henry Positnik and Ronald Nose	Anchorage, AK 99508
Client Address: P O Box 51070	Auditor Phone: (907) 729-3237
Akiachak, AK 99551	Auditor FAX:
Client Phone: (907) 825-2028	Auditor Comment: Phone number and email is for Kevin
Client FAX:	
Design Data	
Building Area: 4,638 square feet	Design Space Heating Load: Design Loss at Space: 345,111
Building Area: 4,638 square feet	<b>Design Space Heating Load:</b> Design Loss at Space: 345,111 Btu/hour
Building Area: 4,638 square feet	<b>Design Space Heating Load:</b> Design Loss at Space: 345,111 Btu/hour with Distribution Losses: 383,457 Btu/hour
Building Area: 4,638 square feet	Design Space Heating Load: Design Loss at Space: 345,111 Btu/hour with Distribution Losses: 383,457 Btu/hour Plant Input Rating assuming 82.0% Plant Efficiency and 25% Safety
Building Area: 4,638 square feet	Design Space Heating Load: Design Loss at Space: 345,111 Btu/hour with Distribution Losses: 383,457 Btu/hour Plant Input Rating assuming 82.0% Plant Efficiency and 25% Safety Margin: 584,537 Btu/hour
Building Area: 4,638 square feet	Design Space Heating Load: Design Loss at Space: 345,111 Btu/hour with Distribution Losses: 383,457 Btu/hour Plant Input Rating assuming 82.0% Plant Efficiency and 25% Safety Margin: 584,537 Btu/hour Note: Additional Capacity should be added for DHW and other
Building Area: 4,638 square feet	Design Space Heating Load: Design Loss at Space: 345,111 Btu/hour with Distribution Losses: 383,457 Btu/hour Plant Input Rating assuming 82.0% Plant Efficiency and 25% Safety Margin: 584,537 Btu/hour Note: Additional Capacity should be added for DHW and other plant loads, if served.
Building Area: 4,638 square feet Typical Occupancy: 0 people	Design Space Heating Load: Design Loss at Space: 345,111Btu/hourwith Distribution Losses: 383,457 Btu/hourPlant Input Rating assuming 82.0% Plant Efficiency and 25% SafetyMargin: 584,537 Btu/hourNote: Additional Capacity should be added for DHW and otherplant loads, if served.Design Indoor Temperature: 70 deg F (building average)
Building Area: 4,638 square feet Typical Occupancy: 0 people Actual City: Akiachak	Design Space Heating Load: Design Loss at Space: 345,111Btu/hourwith Distribution Losses: 383,457 Btu/hourPlant Input Rating assuming 82.0% Plant Efficiency and 25% SafetyMargin: 584,537 Btu/hourNote: Additional Capacity should be added for DHW and otherplant loads, if served.Design Indoor Temperature: 70 deg F (building average)Design Outdoor Temperature: -39 deg F
Building Area: 4,638 square feet Typical Occupancy: 0 people Actual City: Akiachak Weather/Fuel City: Akiachak	Design Space Heating Load: Design Loss at Space: 345,111Btu/hourwith Distribution Losses: 383,457 Btu/hourPlant Input Rating assuming 82.0% Plant Efficiency and 25% SafetyMargin: 584,537 Btu/hourNote: Additional Capacity should be added for DHW and otherplant loads, if served.Design Indoor Temperature: 70 deg F (building average)Design Outdoor Temperature: -39 deg FHeating Degree Days: 13,213 deg F-days
Building Area: 4,638 square feet Typical Occupancy: 0 people Actual City: Akiachak Weather/Fuel City: Akiachak	<ul> <li>Design Space Heating Load: Design Loss at Space: 345,111</li> <li>Btu/hour</li> <li>with Distribution Losses: 383,457 Btu/hour</li> <li>Plant Input Rating assuming 82.0% Plant Efficiency and 25% Safety</li> <li>Margin: 584,537 Btu/hour</li> <li>Note: Additional Capacity should be added for DHW and other</li> <li>plant loads, if served.</li> <li>Design Indoor Temperature: 70 deg F (building average)</li> <li>Design Outdoor Temperature: -39 deg F</li> <li>Heating Degree Days: 13,213 deg F-days</li> </ul>
Building Area: 4,638 square feet Typical Occupancy: 0 people Actual City: Akiachak Weather/Fuel City: Akiachak Utility Information	Design Space Heating Load: Design Loss at Space: 345,111Btu/hourwith Distribution Losses: 383,457 Btu/hourPlant Input Rating assuming 82.0% Plant Efficiency and 25% SafetyMargin: 584,537 Btu/hourNote: Additional Capacity should be added for DHW and otherplant loads, if served.Design Indoor Temperature: 70 deg F (building average)Design Outdoor Temperature: -39 deg FHeating Degree Days: 13,213 deg F-days

Annual Ene	Annual Energy Cost Estimate													
Description	Space Heating	Water Heating	Ventilation Fans	Lighting	Other Electrical	Raw Water Heat Add	Water Circulation Heat	Tank Heat	Total Cost					
Existing Building	\$26,117	\$559	\$131	\$5,039	\$35,422	\$17,903	\$4,222	\$2,500	\$91,894					
With Proposed Retrofits	\$23,135	\$995	\$131	\$2,147	\$30,753	\$4,359	\$1,744	\$1,849	\$65,113					
Savings	\$2,982	-\$436	\$0	\$2,892	\$4,669	\$13,544	\$2,478	\$650	\$26,780					

Building Benchmarks										
Description	EUI	EUI/HDD	ECI							
Description	(kBtu/Sq.Ft.)	(Btu/Sq.Ft./HDD)	(\$/Sq.Ft.)							
Existing Building	434.1	32.85	\$19.81							
With Proposed Retrofits	251.4	19.03	\$14.04							
EUI: Energy Use Intensity - The annual site energy consumption divided by the structure's conditioned area.										
EUI/HDD: Energy Use Intensity per Heating Degree Day.										
ECI: Energy Cost Index - The total annual cost of energy divided by the square footage of the conditioned space in the										
building.										

## Appendix B - Actual Fuel Use versus Modeled Fuel Use

The Orange bars show Actual fuel use, and the Blue bars are AkWarm's prediction of fuel use.







#1 Fuel Oil Fuel Use

Recovered Heat Fuel Use



# **Appendix C - Electrical Demands**

Estimated Peak Electrical Demand (kW)												
	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Current	20.4	20.4	20.4	20.4	20.3	20.3	20.3	20.3	20.3	20.3	20.4	20.4
As Proposed	17.8	17.8	17.8	17.7	17.7	17.6	17.6	17.6	17.7	17.7	17.7	17.8

-----

AkWarmCalc Ver 2.4.1.0, Energy Lib 3/30/2015